



## Enduris™ Roof Coating Standard Warranties

Effective February 14, 2022

### Minimum Dry Film Thickness and Application Rates

	10 year	15 year	20 year	25 year
Types of warranties available	Product (for any installer) Labor & Material (for Approved Applicators)	Product (for any installer) Labor & Material (for Approved Applicators)	Product (for any installer) Labor & Material (for Approved Applicators)	Product Plus (for Approved Applicators)
Minimum mils Dry (DFT) <sup>(1)</sup> Wet	21 dry mils 24 wet mils	28 dry mils 32 wet mils	36 dry mils 40 wet mils	40 dry mils 45 wet mils
Application Rates Theoretical <sup>(1)</sup>  Practical <sup>(2)</sup>	1.5 gallons/SQ  2.0 gallons/SQ	2.0 gallons/SQ  2.5 gallons/SQ	2.5 gallons/SQ  3.0 gallons/SQ	2.8 gallons/SQ  3.4 gallons/SQ
Recoat applications - New coating DFT - Total DFT	15 mils  30 mils minimum	20 mils  35 mils	  Not Available	  Not Available

(1) Theoretical Application Rates to achieve minimum DFT.

(2) Practical Rates are higher to allow for surface texture and porosity, wind loss and material left in container, on rollers and/or spray equipment lines. Each roof and project is different and the practical rate increase will vary.

### Fees

	10 year	15 year	20 year	25 year
Product warranty	No Fee	No Fee	No Fee	Not Available
Product Plus	N/A	N/A	N/A	No Fee
Labor & Material Limited Warranty	\$1,800 plus \$.04/square foot	\$1,800 plus \$.08/square foot	\$1,800 plus \$.12/square foot	Not Available

Note: System warranties for Solar projects may be available for an additional cost. Contact Momentive for more information.

### Approved Products and basecoat requirements (Always test adhesion)

Substrate <sup>(3)(4)</sup>	Basecoat or cleaner
Asphaltic surfaces such as BUR or ModBit	Optional: Asphalt Bleed Blocker to prevent bleed through into light color coating. Apply at 1 gallon/100 sq. ft. (2 gal for new asphalt)
Aged EPDM	Commercial biodegradeable cleaners (Simple Green or similar)
Aged TPO, PVC, Hypalon®	Commercial biodegradeable cleaners (Simple Green or similar)
Metal	None
SPF	2 color systems required over new SPF with min. 15 mil dark basecoat
Structural Concrete	None

(3) Warranties are for GE Silicones coatings and do not include the substrate to which the coating is applied or for basecoats that are not GE Silicones products.

(4) Do not apply to:

- a. Aluminized coatings
- b. Ballasted single-ply membranes
- c. Coal tar